


# CERTIFICATE

Certified Passive House Component  
Component-ID 1611as00 valid until 31st December 2021

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany



Category: Airtightness Systems | **Surface Air Sealing**

Manufacturer: **The A. Proctor Group Ltd**  
The Haugh  
Blairgowrie PH10 7ER  
United Kingdom

Product-System: **Procheck Adapt**

Description: System for surface air sealing

System Components: Airtight membrane „Procheck Adapt“  
Self-adhesive Tape „Wraptite tape“ 75 mm

permeability

**0.07 m<sup>3</sup>/(hm<sup>2</sup>) (±0.006)**

instructions for use

coherent ✓

recommended  
detailing

comprehensive ✓

**This certificate was awarded based on the following criteria:**

Tested under standard boundary conditions the system meets the listed requirements

Class	permeability per unit area @ 50 Pa [m <sup>3</sup> /(hm <sup>2</sup> )]
phA	≤ 0.10
phB	≤ 0.18
phC	≤ 0.25

The manufacturer supplies coherent and comprehensive instructions for use and detailing recommendations for all system components. Adhering to these recommendations the system can greatly simplify the execution of an airtight building fabric. The complete Certification Report may also be downloaded at [www.passiv.de](http://www.passiv.de).



**CERTIFIED  
COMPONENT**

Passive House Institute